



Certificate of Compliance

Applicant: COLUMBIA FIRE, LLC Project Number: G106311173

Referenced Reports: 106311173ATL-001 Certification ID Number: 106311173ATL-001C

Service Center No.: 1

Issuance of this Certificate indicates that the Alarm Service Company outlined in the Applicant section of this Certificate (and P service centers, when applicable) is under Annual Independent Third Party Surveillance by Intertek a Recognized Testing Laboratory and, has been investigated and found to be in effective compliance with the applicable Nationally Recognized Standards outlined within this certificate, can be found in Intertek's Product Listing Directory, and is eligible to use the ETL listing mark in accordance with Intertek standards and policies.

Alarm Service Company Applicant COLUMBIA FIRE, LLC 111 S. Findlay Street Seattle, WA 98108

Service Center: Service Center No.: COLUMBIA FIRE, LLC 111 S. Findlay Street Seattle, WA 98108

The Alarm Service Company has been investigated and found to be in compliance with the following Nationally Recognized Standards and is eligible to perform the following services under the Intertek – ETL listed mark:

Standard(s)::

National Fire Alarm and Signaling Code [NFPA 72:2018 Ed. 2019], National Fire Alarm and Signaling Code [NFPA 72:2015 Ed. 2016], National Fire Alarm and Signaling Code [NFPA 72:2012 Ed. 2013], National Fire Alarm and Signaling Code [NFPA 72:2009 Ed.2010], National Fire Alarm Code [NFPA 72:2006 Ed.2007], and the National Fire Alarm Code [NFPA 72:2002 Ed.2002]).

Listed Services covered by this Certificate:

Install Inspect, Maintain, Test, Issue Alarm System Description Certificates for installed fire alarm systems.

RUNNER SERVICE: The Alarm Service Company (ASC) shall be responsible for maintaining and providing all necessary service under contract to a subscriber in accordance with NFPA 72 Contract Requirements for Central Station Service. The contract shall clearly indicate the runner service will be provided by the listed fire alarm servicelocal company with its own personnel or the listed central station with its own personnel.

Service area(s): Counties within two-hour travel time utilizing land-based vehicle.

Date of Effect: September 8, 2025

Date of Expiration:

Date of Expiration:
September 7, 2026

For Matt Snyder Certification Manager

Miller habe

Intertek Testing Services NA Inc. 545 E. Algonquin Road, Arlington Heights, IL 60005 (T): 847-439-5667 (F) 847-439-7320

This Certification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and it's Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certification. Only the Client is authorized to copy or distribute this Certification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek The observations and test results referenced from Certification are relevant only to the facility evaluated